

Date: August 2016

To: City Council and Public Works & Streets Commission

From: Rick McClung & David Buckwald

Re: August 2016 Monthly Public Works Report

Produced: 5,132,900 Gallons of Drinking Water
Treated: 4.189,000 Gallons of Wastewater

Department	Subject	Description
Streets	Crestview Landslide	Received FEMA grant funds of \$60,065.90
Streets	Side arm mowing	Side arm mowed: Windsong/Hanley—2700 ft. and upper Blackstone—3200 ft.
Streets	Signs	Repaired three broken street signs
Streets	Street repair	Grindings applied to East 2nd at Hwy 101
Streets	Pothole repair	Shellmidden Way.
CIP – Hwy 101	Hwy 101/sidewalks	Mobilization and set-up starts 09/19/16 Storm drain work begins 09/26/16 at 7 th Street, moving south towards 2 nd Street
CIP – Wastewater/Water	Little Excavator Trailer	Small excavator trailer has been delivered.
CIP -Water	Looping Project	Altitude valve installed; allows two booster stations to be on stand-by for emergency use only. Connected to Blackstone 126k gallon reservoir to help meet water demands
CIP -Water	South Reservoir Site	Site appraisal received; council scheduled to discuss purchase/alternatives on 09/15

Water	Fire Hydrants	Cleaned, primed and painted 24 hydrants.
Water	Booster station repair	Repaired pump #1 at Windsong booster station
Water	New meter install	Installed two water meters.
Water	Meter cover	Built and installed a new meter and back-flow assembly cover for the Commons.
Public Works	Fill site	Removed 27 yards of street grindings from skate park area to the WWTP.
Parks & Commons	Playground	Painted yellow safety stripe on top of concrete retaining wall at playground.
Sewer	Wastewater surcharge	Researched possible ways to charge an equitable rate for wastewater stronger than normal wastewater.
Sewer	Sewer main repair	Repaired four feet of 8" sewer main and five feet of 4" sewer lateral at 10th and King St. Pioneer Telephone prepped the site for Public Works to complete the repair.
Sewer	Manhole repairs	Reset a manhole cover to grade on Hill Court. Uncovered manhole that was paved over on Yachats River Rd. Broke loose a manhole lid on Marine Drive. (required jack hammer) Working on Riverside Pump Station repair.
Sewer	Grease removal	25 man-hours to remove grease from all five pump stations.
Sewer	WWTP water tank	Cleaned, primed and painted the non-potable water tank.
Sewer	WWTP annual maintenance	Cleaned digester #3. Removed approximately 8.5 wet yards of grit. Recovered two ½-inch sockets and one cell phone.
Sewer	Biosolids	94,114 gallons of bio-solids were processed to make two truckloads to Roseburg. Appx. 15,500 gallons sent to the land fill.
Sewer/Water	Weekly meetings	Weekly meetings with City Administrator; took her to see Riverside pump station and discuss drainage issues at the property.

