

Date: March 5, 2018
To: Shannon Beaucaire, City Manager
From: Public Works Department
Re: February 2018 Public Works Report

Total Rain fall for the month of February 2018:	5.31 inches
Total Water production:	3,487,600 gallons
Total Wastewater treated:	4,990,000 gallons

Streets:

- Request to cut right-of-way trees on Horizon Hill.
- Filled pot holes and bladed Shellmidden St.

Drainage:

- Completed Cedar Ave. drainage system with a culvert installation.
- Installing two catch basins on 1st St.
- Cleared area around Hanley Terrace culvert.

Water:

- Plant maintenance.
- Cleaned Reedy Creek Headworks.
- Contracted tree inspections at the water plant (storm damage).

Distribution Sys:

- Read Meters.
- Completed 2" water line repair on Horizon Hill.
- Flushed water distribution system—64 manhrs.
- Meter shut off on Surfside (property side broken).
- Replaced 2" water meter for 142 Hwy 101 N.
- New water meter install on Surfside Drive.
- Repaired water line leak at 961 Ocean View Drive (2.5 gpm) and at a property South of the bridge (2.0 gpm).

Sewer:

- Plant maintenance.
- Completed and submitted 2017 Annual Biosolids Report to DEQ.

Collection Sys:

- Investigated sewer line connection at 873 Horizon Hill.
- Parkside generator repairs complete and back in service.

Sewer & Water CIP:

- 65 feet of pipe installed on the Driftwood water line CIP project.

Parks & Commons & 501 Bldg:

- Applied roofing tar to drain pipe in Commons attic.
- Moved lager items from Commons basement to trash dumpster.
- Removed asphalt from cover dirt on baseball field storm culvert.

Public Works:

- Vehicle maintenance.
- Shop maintenance.
- Installed a post at the brush box gate at Public Works.
- New brakes on Fleet truck.
- New 5-yd dump truck needed a hydraulic cylinder welded. Completed.
- Put up and removed US flags for Presidents Day.
- Adjusted Light timer for the Picnic Shelter.

Emergency Preparedness:

- Still waiting for GPS points for Blue Line placement.