



City of Yachats

Public Works Department
500 W. 7th St.
P.O. Box 345
Yachats, OR 97498

Date: April 4th, 2016

To: City Council and Public Works & Streets Commission

From: Rick McClung & David Buckwald

Re: March 2016 Public Works Report **Subject:** Work Outside of Normal Operations

Department	Subject	Description
Commons	Exterior Doors	9 out of 10 doors are completed, still have 1 to go
Commons	Outside Lights	New lights for the reader board
Water	Leak Detection	Hired leak detection company, found about 20 gpm total in water leaks
Water	SCADA	SCADA system is installed, now doing integration of information
CIP- Water	South Reservoir	100% nearly complete

CIP- Water	101 Waterline Replacement	Project nearly complete
CIP-Water	Surfside & Reeves Circle waterline replacement	Work has begun
Wastewater	Biosolids	Biosolids hauling season has begun. (Heard Farms, Roseburg)
Wastewater	Spare pump station pumps	A spare pump for Parkside and Pontiac pump stations have been ordered.
CIP Wastewater	Decant Center	DEQ has approved the engineered plans and now will be sent to bid.
Water Wastewater	5 years CIP Planning	Preliminary planning complete, ready to move forward with finance committee input